

# WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. 027901

Water Right Permit No. \_\_\_\_\_

(1) OWNER: Name J A Schwager (STANLEY) Address W. Smugglers Cove Rd Greenbank WA

(2) LOCATION OF WELL: County ISLAND NE 1/4 SW 1/4 Sec 18 T. 30 N., R. 2 E W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) Smugglers Cove Rd. Greenbank

(3) PROPOSED USE: ☐ Domestic ☐ Industrial ☐ Municipal ☐  
☐ Irrigation ☐ Test Well ☒ Other ☐  
☐ DeWater

(4) TYPE OF WORK: Owner's number of well (if more than one) \_\_\_\_\_  
Abandoned ☐ New well ☒ Method: Dug ☐ Bored ☐  
Deepened ☐ Cable ☒ Driven ☐  
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.  
Drilled 222 feet. Depth of completed well 222 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 0 ft. 217 1/2 ft.  
Welded ☒ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Liner installed ☐ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Threaded ☐ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Perforations: Yes ☐ No ☒

Type of perforator used \_\_\_\_\_  
SIZE of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Screens: Yes ☒ No ☐

Manufacturer's Name COOK  
Type STAINLESS Model No. \_\_\_\_\_  
Diam. 6 Slot size 15 from 217 ft. to 222 ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Gravel packed: Yes ☐ No ☒ Size of gravel \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft.  
Material used in seal BENTONITE  
Did any strata contain unusable water? Yes ☐ No ☐  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
HARD PAN	0	72
DRY DIRTY SAND	72	122
SANDY HARD PAN	122	168
WATER SAND (10 GPM)	168	175
CLAY	175	214
WATER SAND	214	222

RECEIVED

MAR 08 1990

DEPARTMENT OF ECOLOGY  
NORTHWEST REGION

Work started \_\_\_\_\_, 19. Completed MARCH, 1990

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME WHIDBEY DRILLERS  
(PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address OAK HARBOR WA.

(Signed) Paul John License No. 129  
(WELL DRILLER)

Contractor's  
Registration No. W-110-BUDCOFF Date MAR, 1990

(USE ADDITIONAL SHEETS IF NECESSARY)